

	Sri Devaraj Urs College of Nursing	Format No.	ADM 15
	Tamaka, Kolar - 563 103, Karnataka.	Issue No.	02
	Facilities Maintenance Logbook	Rev. No.	00
	<i>Electrical</i>	Date	01-09-2018

- 17 ROOM NO - (15)
New Regulator
work done
- 18 ROOM NO - (30)
New Regulator
New Capacitor
work done
- 19 ROOM NO - (42)
Switch work done
- 20 ROOM NO - (41)
New Socket
work done
- 21 ROOM NO - (43)
New Capacitor
work done
- 22 ROOM NO - (44)
New Socket
work done
- 23 ROOM NO - (53)
New Capacitor
work done
- 24 ROOM NO - (54)
New Socket
work done
- 27 ROOM NO - (31)
New Tubelight
work done

Monos
work done
Vandha

DK
gus

Date: 23/04/2025

- 1. Room - 48 Le fit led fitting
New Regulator
work done

- 2 Room 107 Lemalle Box
Switch, Socket
Dumny, Cap
Capacitor also
work done
- 3 Room 28 5 Amps Switch
New replaced
work done

Date: 25/04/25

- (1) Room - 29 Fan
New Capacitor
work done
Monos

College work 19/05/25

- (1) OBE Fans light same
(2) CHN Connexion
(3) Lights & not working
(4) BSC(N) 3rd year
4th year
2nd year GNM
1st year GNM
Switch Guard
has been
repaired
Grew fixed
completed
work done
Arunakumar
Narayanan
Krishna

DK
gus
SK

Date: 20/5/25

1. Room No. 48 Fan works slow Work done & repair
2. 83 Fan & switch board not working & slow Work done & repair
3. 102 Switch board is not working (fuse) Board new replaced work done
4. 27 Plug wire disconnected & 1 (short) Work done & repair

Date: 29/05/25

5. 129 New Tubelight work done

- ⑥ 48 New Socket work done

- ⑦ 80 New Capacitor Fan work done

- ⑧ 100 New Regulator work done

- ⑨ 32 New Socket work done

- 10 5 New Capacitor work done

Date: 27/5/25

1. Room: 80 Fan Not working Work done Repair

- Date: 2/6/25 Room: 33
Fan coming noise Repair done

- 5/6/25 Room: 33 light not working New replaced

- 6/6/25 Room: 80 Fan Complaint New replaced
11 25 Plug Point not working Replaced done

- 7/6/25 33 Tube light New replaced
15 Fan Sound repair
5 Switch board not stock

- 15/6/25 123 Switch board not working repair done

- 16/6/25 16 Right side switch repair done
Damage Tubelight

- 23/6/25 81, 49, Regulator not working repair done

- 3/7/25 32 Fan Not working repair done

- 7/7/25 13 light blinking New replaced done

- 14/7/25 40 light & switch Board repair done

	Sri Devaraj Urs College of Nursing		Format No.	ADM 15
	Tamaka, Kolar - 563 103, Karnataka.		Issue No.	02
	Facilities Maintenance Logbook		Rev. No.	00
	<i>Plumbing</i>		Date	01-09-2018

S.D.O. C.O. NH,

S.No	DATE	COMPLAINT	NAME of Attending Person
35	11/09/23	1st Floor Bathroom Tap water leakage problem	Srinivas
36	12/10/23	Water is ^{not} coming from ^{some} tap in ground floor, 1st floor and 2nd floor.	Srinivas
37	12/10/23	blockage of toilets in ground floor and 1st, 2nd and 3rd floor.	
38	12/10/23	Flush of western toilets is not working properly in staff rooms of 2nd and 3rd floor.	Srinivas
(39)	15/01/25	2 nd floor wash room Water Tap Replaced (2)	Chinnaraj
40	29/05/25	2 nd floor bathroom water taps New (5) replaced work done	A. S.
41	21/7/25	Kitchen water pipe Damage Repair done	Srinivas

Work Done	Signature	Remarks
Water Tap Replaced Work Completed		Work Done Cleared. V. Srinivas
Work is in process.		
Working		
Work done		
Work done		